

**EIP Rincmd
Initiate Instance
(written by PLC)**

Command = 0x16
Register ID = 0x0005
Data = 0

**Rincmd
Protocol**

Command change initiates command and clears result

20160005;;

Rincmd message
sent to C500-K501

80160005:3382145;

**EIP Rincmd
Result Instance
(read by PLC)**

Status = 0x1 (in progress)
Command = 0
Register ID = 0
Data = 0

Response to command populates result

Status = 0x10 (success)
Command = 0x16
Register ID = 0x0005
Data = 3382145