

EIP Simple Operation

Initiate Instance (written by PLC)

Command = 1000
Data = 12345

Rincmd Protocol

EIP Simple Operation

Result Instance (read by PLC)

Command change initiates command and clears result

2012A408:3E8;

Rincmd message
sent to C500-K501

8012A408:0000;

Status = 0x1 (in progress)
Command = 0
Data = 0

Response to command populates result

Status = 0x10 (success)
Command = 1000
Data = 0