



EU-type examination certificate

Number **T7418** revision 1

Project number 2223540

Page 1 of 1

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in Article 13 of Directive 2014/31/EU, after
having established that the measuring instrument meets the applicable
requirements of Directive 2014/31/EU, to:

Manufacturer Rinstrum Pty Ltd.
41 Success Street
Acacia Ridge, QLD 4110
Australia

Measuring instrument **A Non-automatic weighing instrument**
Type : X3xx

Further properties are described in the annex:
– Description T7418 revision 1.

Valid until 30 May 2028

Remarks This revision replaces the earlier version.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
30 October 2018


C. Oosterman
Head Certification Board

NMI Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMI Certin B.V. as Notified
Body can be verified at
[http://ec.europa.eu/growth/tools-
databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete
document only is permitted.



1 General information about the non-automatic weighing instrument

All properties of the non-automatic weighing instrument, whether mentioned or not, shall not be in conflict with the legislation.

This certificate contains references to other certificates. The properties mentioned in these certificates shall be observed in addition to the properties mentioned in this certificate.

1.1 Essential parts

Indicator:

Producer	Type	Certificate number
Rinstrum	X3xx	TC7419

Any load cell(s) may be used under this certificate for instruments as described in WELMEC 2.4 Issue 2, provided the following conditions are met:

- There is a respective certificate (EN45501) or an OIML Certificate of Conformity (R 60) issued for the load cell by a Notified Body responsible for type examination under Directive 2014/31/EU.
- The certificate contains the load cell types and the necessary load cell data required for the manufacturer's declaration of compatibility of modules (WELMEC 2, 2015 clause 10), and any particular installation requirements. A load cell marked **NH** is allowed only if humidity testing to EN45501 has been conducted on this load cell.
- The compatibility of load cells and indicator is established by the manufacturer by means of the compatibility of modules form, contained in the above WELMEC 2 document, at the time of putting into use.
- The load transmission must conform to one of the examples shown in WELMEC 2.4 Issue 2.

1.2 Essential characteristics

Accuracy class	Ⓐ or Ⓑ
Weighing range(s)	Single interval
Maximum number of scale intervals	$n \leq$ number of scale intervals in the certificates involved

1.3 Essential shapes

The data plate is secured against removal by sealing or will be destroyed when removed.

1.4 Conditional parts

The non-automatic weighing instrument may be equipped with peripheral equipment which is used for the applications listed in Article 1(2), (a) to (f) of Directive 2014/31/EU, provided that the peripheral equipment is certified to be connected to a non-automatic weighing instrument by a Notified Body responsible for type examination under Directive 2014/31/EU, or, that the equipment and the use of the equipment complies with the requirements of WELMEC 2.5 Issue 2 clause 2.2.

Number **T7418** revision 1

Project number 2223540

Page 2 of 2

The non-automatic weighing instrument may be equipped with a Point Of Sale (POS) or an Electronic Cash Register (ECR), provided that the POS and ECR are certified to be connected to a non-automatic weighing instrument by a Notified Body responsible for type examination under Directive 2014/31/EU.

The non-automatic weighing instrument may be equipped with Electronic Funds Transfer equipment (EFT/ECU), if the EFT/ECU represents only the price total on the display.

The non-automatic weighing instrument is fitted with a levelling device and a level indicator, unless the instrument is installed in a fixed position. The level indicator has a sensitivity of at least 2 mm for a tilt of 2/1000.

1.5 Non-essential parts

The non-automatic weighing instrument may be connected to non-essential devices, for example but not limited to bar code readers, foot switches, second displays and cash drawers, provided that:

- They do not present primary data used for purposes mentioned in Article 1(2), (a) to (f) of Directive 2014/31/EU unless the "Preliminary observation" in Annex I of the Directive is satisfied;
- They do not lead to an instrument having other essential characteristics than those fixed by this certificate.

2 Seals

To secure components that may not be dismantled or adjusted by the user, the non-automatic weighing instrument has to be secured in a suitable manner on the locations indicated in the certificates involved.

The connecting cable of the load cell or the junction box is provided with the possibility to seal.

3 Conditions for conformity assessment

The marks, facilities for the marks and the inscriptions on the non-automatic weighing instrument fulfil the requirements of point 1 of Annex III of Directive 2014/31/EU.

The compatibility of load cells and indicator is established by the manufacturer by means of the compatibility of modules form, contained in WELMEC 2, 2015 clause 10, at the time of putting into use.

In case the non-automatic weighing instrument is equipped with a Point Of Sale the conformity assessment procedure of WELMEC 2.2 Issue 3 clause 2.2 shall be taken into account.